[redacted]

From: William Treves (Economy Transport and Environment) <William.Treves@derbyshire.gov.uk>
Sent: 02 March 2021 17:28
To: Penford, Mark <Mark.Penford@ambervalley.gov.uk>
Subject: RE: [OFFICIAL] FW: Storm water connection AVA/2020/0894 - 2 The Green, Kirk Langley

Good Afternoon,

Thank you for the email below. As it would be a novel connection through a reinforced concrete sectional culvert which in itself could put the culvert structure at risk then the LLFA would agree that it seems reasonable for discharge to be through the nearby public sewer to be agreed through Severn Trent Water.

Kind regards

William Treves | Flood Risk Technician

Flood Risk Management Team

(The DCC Flood Risk Team are now working from home until further notice, due to the Covid 19 Virus. This should not affect any of the services we provide on a day to day basis)

Economy, Transport and Environment | Derbyshire County Council
County Hall, Matlock, Derbyshire, DE4 3AG

T 01629 538571 **M** 07812473023

E William.treves@derbyshire.gov.uk

www.derbyshire.gov.uk/environment/flooding/strategy

[redacted]





