[redacted]

Hello Mark and Sean,

Thank you for confirming the void height Sean. My concern is whether further measures may be required to protect against mine gas. If the skirting had some openings/vents then the void would allow any mine gas to be vented. Would this be possible to incorporate into the design? I also forgot to ask what kind of surface the buildings will be placed on.

Kind regards,

Rowena

**Rowena Bailey | Scientific Officer**

**Amber Valley Borough Council**
Operations | Town Hall, Market Place, Ripley, Derbyshire, DE5 3BT
**Email**: rowena.bailey@ambervalley.gov.uk







