From: Bailey, Rowena
Sent:20 May 2021 08:28:36 +0100
To: Development
Cc: Penford, Mark
Subject:RE: Planning Consultation - AVA/2021/0532 and AVA/2021/0544

Mark,

Thank you for consulting me on these applications.

The applicant has confirmed that the modular buildings will be raised with a void underneath, and that this void will be ventilated. I would be grateful if the following advisory note could be attached to any permission granted:

The applicant should be made aware of the importance of keeping the void under the modular building clear and maintaining ventilation grilles to allow the dispersal of ground gases.

Regards,

Rowena

Rowena Bailey | Scientific Officer

[redacted]

