Julian Townsend
Executive Director (Operations)
Development Management

Town Hall
Ripley
Derbyshire DE5 3BT
Tel: 01773 570222
Fax: 01773 841523
Email: enquiry@ambervalley.gov.uk
Web: www.ambervalley.gov.uk

R Fallows
The Cottage
Burlegh Drive
Derby
DE22 1AL

Mr David Brown
5 Maes Yr Eglwys
Llansaint
Carmarthen
SA175JE

TOWN AND COUNTRY PLANNING ACT 1990

In pursuance of the powers vested in the Amber Valley Borough Council under the above Act and Orders and taking into account Government guidance and policy and the saved policies of the Adopted Amber Valley Borough Local Plan 2006, and with reference to your application (**Office Code: AVA/2020/1025**) which was valid on the 30 October 2020 for permission for **Change of use from Public house to Beauty Salon (Sui generis) and enclosing rear patio area to form cafe (Use Class E(b)), including new flat roofs with rooflights, and alterations to the store building to form a kitchen, including erection of a flue and alteration to the roof pitch at Wheel Inn 14 Chapel Street Holbrook**

In the manner described in the application and shown on the accompanying plan(s) and drawing(s) **NOTICE IS HEREBY GIVEN** that permission for the proposed development is **GRANTED subject to the following conditions:**

Conditions/Reasons

1. The development hereby permitted shall be begun before the expiration of three years from the date of this permission.

   Reason: To comply with the requirements of Section 91(1) of the Town and Country Planning Act, 1990, as amended by Section 51 of the Planning and Compulsory Purchase Act 2004.

Date : 23 June 2021

Signed

Julian Townsend
Executive Director (Operations)

2. The development shall be carried out in accordance with the details contained in the submitted plans and documents listed below and with the conditions attached to this permission:

   site location plan - drawing 876/03
   proposed floor plans and elevations - drawing 876/01 Revision A

   Reason: In order to define the permission

3. Notwithstanding the provisions contained within Schedule 2, Parts 3 and 4 of the Town and Country Planning (General Permitted Development)(England) Order 2015 (or any Order revoking and re-enacting that Order) this permission shall relate to the use of the premises only for the purposes defined in the application, namely beauty salon (sui generis) and café (Use Classes E(b)) (as set out in the Town and Country Planning (Use Classes) (Amendment) (England) Regulations 2020, and for no other purpose unless planning permission for a new use of the premises has been granted by the Local Planning Authority.

   Reason: To enable the Local Planning Authority to maintain a satisfactory control of the activities involved in accordance with policy EN16 of the Adopted Amber Valley Borough Local Plan 2006.

4. No work on the conversion of the terrace and store building shall commence until details of the external facing and roofing materials, including details of the roof lights and windows including colour finish have been submitted to and agreed in writing by the Local Planning Authority. The scheme shall subsequently be implemented in accordance with the approved details.

   Reason: To ensure the satisfactory appearance of the completed development in accordance with saved policies LS3 and EN27 of the Adopted Amber Valley Borough Local Plan 2006.

5. Before the café use hereby permitted begins, and before it is installed, details of equipment to control the emission of fumes and smell from the premises, as well as the associated level and character of noise emissions, shall be submitted to and approved in writing by the Local Planning Authority. The equipment shall subsequently be installed and maintained in perpetuity in accordance with the approved details.

Date : 23 June 2021

Signed

Julian Townsend
Executive Director (Operations)

The system shall be appropriate to the nature and quantity of cooking done and sufficient to control the emission of smell and noise from the premises such that the residential amenity of nearby premises is not materially affected. This equipment shall be used whenever cooking is taking place and shall be switched off no later than fifteen minutes after the premises are required to close. The equipment shall be installed, operated and maintained in accordance with the manufacturer's instructions and retained for so long as the use continues. Records documenting the level of maintenance and servicing shall be kept, and available for inspection, for at least the preceding 2 years.

Following installation, if an assessment of odour or noise emissions from the kitchen extraction system by the local planning authority determines that further mitigation is required, appropriate measures shall be taken in accordance with a scheme to be approved in writing by the Local Planning Authority within an agreed period.

Reason: In the interests of protecting amenity in accordance with saved Policy EN16 of the Adopted Amber Valley Borough Local Plan 2006.

6. The uses hereby permitted (hair/beauty salon and café), including the café kitchen extraction system, shall not operate, and no deliveries shall be taken at or despatched from the site, at any times other than between 08:00 and 21:00hours Mondays to Saturdays; and 09:00 and 16:00hours Sundays/bank holidays/public holidays.

Reason: In the interests of protecting amenity in accordance with saved Policy EN16 of the Adopted Amber Valley Borough Local Plan 2006.

7. Prior to the hereby approved use being brought into use a grease trap/filtration system (or a suitable alternative) shall be installed in the drainage system to remove fats, oils, grease and solid matter from the waste water before it leaves the premises. The equipment shall be installed, operated and maintained in accordance with the manufacturer's instructions and retained for so long as the use continues.

Reason: In the interests of protecting amenity in accordance with saved Policy EN16 of the Adopted Amber Valley Borough Local Plan 2006.

8. The flue to be located on the rear of the store building, as shown on drawing 876/01 Rev A, shall be painted matt black in colour within 2 months of installation, and maintained in such condition for the lifetime of the development.

Date : 23 June 2021 Signed



Julian Townsend
Executive Director (Operations)

Reason: To ensure the satisfactory appearance of the completed development in accordance with policy LS3 and EN27 of the Adopted Amber Valley Borough Local Plan 2006.

9. Prior to the hereby approved cafe use being brought into use, the existing flue attached to the eastern elevation of the building shall be removed and the elevation made good.

Reason: In the interests of the visual amenity of the area in accordance with Saved Policies LS3 and EN27 of the Adopted Amber Valley Borough Local Plan 2006.

Notes
Attention is drawn to the attached notes:

1 Advisory Note: Condition 5
In general, the adequacy of a kitchen cooking extraction/ventilation system for dealing with cooking odours will depend on the nature and quantity of cooking done. The proposed system should be risk assessed and designed in accordance with EMAQ's best practice document: 'Control of odour and noise from commercial kitchen exhaust systems' (05 September 2018). Appendix 2 provides guidance on the information required to support planning applications for commercial kitchens; Appendix 3 provides guidance on risk assessing odour; and Appendix 4 provides guidance on factors to take into account in noise assessment.

In general, if food is to be cooked, fried or boiled, the kitchen cooking extraction/ventilation system should include the following elements:
Supply air intake;
Ductwork - properly sized extract and supply ductwork to minimise air noise and resistance to airflow, with balanced spigot connections to distribute air along the length of the canopy;
Coarse/Grease separation (primary filtration);
Fine separation (secondary filtration) (e.g. panel filter, bag filter, electrostatic filter);
Odour control component (e.g. activated carbon, UV-c/ozone) sited under negative pressure (pre fan);
Flexible connections to isolate fan noise and transmission through the duct;
Odour control filters for future cleaning and maintenance should also be considered. The preceding ducting may include a silencer positioned appropriately to reduce fan noise at the extract point. Anti-vibration mounts may also be needed;

Date : 23 June 2021 Signed



Julian Townsend
Executive Director (Operations)

A stack (chimney) discharging 1m above the roof ridge of any building within 15m of its discharge point, with an efflux velocity of 15m/s; the next best scenario would be a terminal point 1m above the eaves, with an efflux velocity of 10-15m/s, but more odour control would be needed. The airflow from the end of the stack must be unimpeded; i.e. the final opening of the chimney must discharge vertically upwards and must not be fitted with any restriction such as a plate, cap or cowl; an accelerator cowl may be fitted to promote upward velocity, improving dispersion.

The operator is strongly advised to submit details of the proposed kitchen extraction system for the approval of the Local Planning Authority prior to installation to ensure that adequate odour suppression and dispersion measures are included, and that the system satisfies both residential and visual amenity requirements.

2 Advisory Note: Condition 7

Disposing of fats, oils and grease (FOG) in drainage systems can cause the build-up of fatty deposits in drains and sewers, leading to blocked pipes (particularly in old properties where the pipework is inadequate or damaged), bad smells and flooding. Guidance in both the Building Regulations 2010 (Approved Document H: 'Drainage and waste disposal', 2015) and from Severn Trent Water recommend that drainage serving kitchens in commercial hot food premises is fitted with a grease separator or other effective means of removal to collect and separate grease during cooking and washing-up. Further advice on the location, size and suitability of grease traps, as well as the legal requirements, can be obtained from Severn Trent Water at: https://www.stwater.co.uk/my-supply/waste-water/looking-after-your-sewers/how-to-avoid-blockages-in-a-commercial-kitchen/ or by calling 0121 809 2100 for advice on installing a grease trap.

3 Development Low Risk Area - Standing Advice

The proposed development lies within a coal mining area which may contain unrecorded coal mining related hazards. If any coal mining feature is encountered during development, this should be reported immediately to the Coal Authority on 0345 762 6848.

Further information is also available on the Coal Authority website at: www.gov.uk/government/organisations/the-coal-authority

Date : 23 June 2021 Signed



Julian Townsend
Executive Director (Operations)

Reasons for Granting Permission

In granting permission for this development the Borough Council has taken into account all material planning considerations arising from the views of statutory and other consultees and public representations about the application, Government guidance as detailed in the National Planning Policy Framework and the saved policies of the Adopted Amber Valley Borough Local Plan 2006:

LS1 - Sustainability criteria
LS3 - Design
TP1 - Impact on the Transport Network
TP6 - Parking
LC11 - Community Facilities
TC8 - Food and Drink
ER11 - Quality and design of development
EN16 - Pollution
EN18 - Derelict, Unstable And Contaminated Land
EN27 - Conservation Areas

In detail:

The National Planning Policy Framework (NPPF) is a material consideration in planning decisions. In accordance with Paragraph 38 of the NPPF the local planning authority has approached the decision making process in a positive way to foster the delivery of sustainable development and has worked proactively with the applicant/agent to secure a development to improve the economic, social and environmental conditions of the area.

The development complies with the provisions of the development plan for the locality and raises no unresolved issues in relation to the location of the site, privacy, amenity, character and design, landscape or heritage features and highway safety.

Date : 23 June 2021

Signed

Julian Townsend
Executive Director (Operations)

NOTES

1. **If the applicant is aggrieved by the decision of the Local Planning Authority to refuse planning permission or approval for the proposed development or to grant permission or approval subject to conditions, he may appeal to the Secretary of State for the Environment in accordance with Section 78/79 of the Town and Country Planning Act 1990, within six months of the date of this notice. The Secretary of State has power to allow a longer period for the giving of a notice but will not normally be prepared to exercise this power unless there are special circumstances which excuse the delay in giving notice of appeal. The Secretary of State is not required to entertain an appeal if it appears to him that permission of the proposed development could not have been granted by the Local Planning Authority or could not have been so granted otherwise that subject to the conditions imposed on them, having regard to the statutory requirements, to the provision of the development order, and to any directions given under the order.**
2. **Cadent Gas own and operate the gas infrastructure within the area of your development. Contact Cadent's Plant Protection Team for approval before carrying out any works on site and ensuring requirements are adhered to. Email plantprotection@cadentgas.com. Alternatively you can register on www.beforeyoudig.nationalgrid.com**
3. **If permission to develop land is refused or granted subject to conditions, whether by the Local Planning Authority or by the Secretary of State for the Environment, and the owner of the land claims that the land has become incapable of reasonably beneficial use in its existing state and cannot be rendered capable of reasonably beneficial use by the carrying out of any development which has been or would be permitted, he may serve on the Council of the County/District in which the land is situated, a purchase notice requiring that council to purchase his interests in the land in accordance with the provisions of Section 180 of the Town and Country Planning Act 1990.**
4. **In certain circumstances a claim may be made against the Local Planning Authority for compensation where permission is refused or granted subject to conditions by the Secretary of State on appeal or on a reference of the application to him. The circumstances in which such compensation is payable are set out in Sections 137 and 138 of the Town and Country Planning Act 1990.**
5. **This permission relates to planning controls only. Any other statutory consent necessary including submission under the building regulations must be obtained from the appropriate Authority.**
6. **If it is intended to give notice of appeal in accordance with Paragraph 1 above, this should be done on the appropriate form obtainable from:-**

   The Planning Inspectorate
   3/23 Hawk Wing, Temple Quay House, 2 The Square Temple Quay Bristol BS1 6PN
   (Tel. No. 0117 372 8000) www.planning-inspectorate.gov.uk

7. **If the condition of consent or reasons for refusal, make reference to a Division of the Department, the appellant may, if he so wishes, require the attendance of a representative from the Department by notification to the Local Planning Authority. Such a representative would not be liable to cross-examination on questions of departmental policy, but only on matters of fact and expert opinion in relation to the appeal site.**
8. **Where a vehicle is habitually drive across a grass verge or kerbed footway to and from premises adjoining a highway, the occupier of the premises may after being given due notice by the appropriate authority, be required to pay the cost of construction of a carriage crossing or the strengthening of a footway, as the authority considers it necessary, or may be required to comply with conditions imposed by the authority.**
9. **In the case of building or premises to which the public are to be admitted whether on payment or otherwise, attention is drawn to Sections 4 and 7 of the Chronically Sick and Disabled Persons Act 1970 and the associated Code of Practice (BS5810:1979). In the case of premises to which the Offices, Shops and Railway Premises Act 1963 or the Factories Act 1962 applies, attention is drawn to Sections 7 and 8A of the Chronically Sick and Disabled Persons Act and to the same code of practice. In the case of Educational Buildings, attention is drawn to Sections 7 and 8 of the Chronically Sick and Disabled Persons Act 1978 and to the Design Note 18 "Access for the Physically Disabled Educational Buildings".**
10. **If the development site is crossed by an electric line or is within 15 metres (50ft) of the nearest part of a line (measure horizontally along the ground) or if there is reason to believe that it may be crossed by an underground electric cable, the applicant should contact the Electricity Board to ascertain if and what special safety precautions are necessary.**
11. **The grant of planning permission does not entitle developers to obstruct a public right of way. Development on so far as it affects a right of way, should not be started, and the right of way should be kept open for public use, until the necessary order under Section 247 and 257 of the Town and Country Planning Act 1990 for the diversion of extinguishment of the right of way has been made and confirmed.**