ALL DIMENSIONS TO BE CHECKED BY CONTRACTOR

FFL 102.000

FFL 93.000

Key :

- FFL 93.000 — Finished Floor Level
- Highway Drainage and Gully Connection to Swale (Not shown)
- Highway Swale
- Surface Water Drainage
- Porous Paving Parking Bay
- Linear Drainage Channel
- Bypass Petrol Interceptor
- Rainwater Harvesting Tank (Indicative - Size TBC by specialist to meet requirements for each unit)
- Foul Water Drainage
- Banking Works (max 1:3 unless otherwise stated)
- 1.15 — Fall Arrow
- 600 0.5m — Retaining Wall (Max height shown)

SURFACE WATER DESIGN SUMMARY

Overall Site Developed Area - 23 Ha

Development Impermeable Area - 10.1 Ha

The surface water drainage strategy has been prepared in accordance with the principles set out in Inspire Flood Risk Assessment GHL-1355-01-FRA - 002 April 2019

The discharge rate has been restricted to Qbar greenfield runoff rate.

As the impermable area of development has reduced since FRA was approved so discharge rate has been reduced on a pro rata basis to accord with reduction in impermable area to 53.0 l/s for all storm events upto and including critical 100yr + 40% CC storm event. Attenuation basin is sized according to provide storage volume required due to discharge rate restriction.

No urban creep allowance has been applied to Industrial Estate areas.

Surface Water system has been design in accordance with principles set out in the FRA including water quality treatment using a combination of SuDS techniques in accordance with Simple index method.

Surface Water discharges to be outfall via headwall at 53 l/s into Denby Bottle Brook

REV	AMENDMENT	BY	DATE
P2	Indicative bunds removed	MWA	01.03.2022
P1	Attenuation Pond - Additional information added	MWA	17.12.2021
P0	First Issue	MWA	10.12.2021

PROJECT EXECUTION CLASS: N/A

All materials supplied in relations to those specified on this drawing are to be CE marked in accordance with the European Union Declaration of conformity

PURPOSE OF ISSUE

PRELIMINARY

COUCH
Consulting Engineers
Civil & Structural

The Old Forge, Priory, London Road, Cantwell, Sutton Coldfield. B73 5SH
Tel: 0121 308 7557
info@ccemg.co.uk

14-16 St. Nicholas, Church Street, Warwick. CV34 4JD
Tel: 01926 409 036

Genesis Centre, 18 Innovation Way, Stoke-on-Trent. ST6 4BF
Tel: 01782 368 160

www.ccemg.co.uk

CLIENT: GARNER HOLDINGS LTD

PROJECT: PHASE 2 DENBY HALL BUSINESS PARK

DRAWING TITLE: DRAINAGE STRATEGY SHEET 1 OF 3

SHEET SIZE	SCALE	DATE	DRAWN	CHECKED	STATUS
A0	1:500	DEC 2021	MWA	CCE	-

CCE PROJECT No.	DRAWING No.	REV
C8093	8093-C-110	P2

© Copyright. This drawing and any design therein is the copyright of Couch Consulting Engineers (Midlands) Ltd and must not be reproduced or utilised without their written consent.