From:Gemma Statham (Place)
Sent:Tue, 17 Jan 2023 13:56:05 +0000
To:Anthony, Laura
Subject:FW: [OFFICIAL] FW: [OFFICIAL] FW: [OFFICIAL] RE: AVA/2022/0965 - 13 Moseley Street, Ripley

Hi Laura

[redacted]

Unless a plan can be submitted demonstrating that a 5m depth can be achieved across the entire site frontage the application is open to objection as previously stated.

Should the drawings be amended to show just the single parking space measuring 5m x 2.5m and the redundant access to be closed, this would be acceptable to the Highway Authority.

If you require any additional information please contact me.

Regards

Gemma Statham | Senior Technician - Development Control | Place | County Hall, Matlock, DE4 3AG | 01629 538519 www.derbyshire.gov.uk
Working Days | Monday | Tuesday | Wednesday
Derbyshire County Council - Improving life for local people
ü Please consider the environment before printing this e-mail

[redacted]

[redacted]







[redacted]