From:Anthony, Laura
Sent:10 May 2023 12:57:09 +0100
To:Development
Subject:FW: [OFFICIAL] FW: AVA/2022/1099 URGENT

Please ack and attach

From: Gemma Statham (Place) <Gemma.Statham@derbyshire.gov.uk>
Sent: 10 May 2023 07:55
To: Anthony, Laura <Laura.Anthony@ambervalley.gov.uk>
Subject: RE: [OFFICIAL] FW: AVA/2022/1099 URGENT

Morning Laura

The visibility plan does not show the 2.4m x point in the right position, the 2.4m x distance is measured from the edge of the carriageway 2.4m back into the access. Also the wall is still shown over 1m in height within the splay area. The visibility splay needs to be clear of all obstructions greater than 1m in height above the carriageway channel level.

Regards

Gemma Statham | Senior Technician Development Control | Place | County Hall, Matlock, DE4 3AG | 01629 538519 www.derbyshire.gov.uk

Working Days | Monday | Tuesday | Wednesday

Derbyshire County Council - Improving life for local people

ü Please consider the environment before printing this e-mail

From: Anthony, Laura <Laura.Anthony@ambervalley.gov.uk>
Sent: 09 May 2023 16:45
To: Gemma Statham (Place) <Gemma.Statham@derbyshire.gov.uk>
Subject: [OFFICIAL] FW: AVA/2022/1099 URGENT
Importance: High





